

Overview

Inverter AC OCP: Per nameplate output current, with conductor ampacity and breaker rating not less than 125% of continuous output. Backfeed allowances must observe busbar ratings and load-side interconnection limits. With inverter-based resources, fault current is curtailed by control electronics.

PV inverter output overcurrent protection

Contact Us

For catalog requests, pricing, or partnerships, please visit:
<https://www.websparafotografos.es>